

STANISLAUS CONSOLIDATED FIRE PROTECTION DISTRICT
POLICIES & PROCEDURES

ARTICLE: C-24
SECTION: Operations Division
DATE: 12/11/97
SUPERSEDES:
TITLE: **RELIEF VALVES**

The relief valve on all engines shall be set at 150 p.s.i. and shall be checked daily to ensure proper setting. The starting pressure for all 1.5 and 1.3/4 inch attack lines shall be 100 p.s.i. at the nozzle.

The relief valve may be adjusted to meet current needs at each incident, however when the engine is placed back in service, the relief valve shall be set at 150 p.s.i.

END

Written By: Michael R. Wilkinson

Date: December 11, 1997